

Annexure C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No.

Dated:

It is certified that an inspection team headed by Tilak Maharashtra Vidyapeeth

(Name of Officers with designation) from (Tilak Maharashtra Vidyapeeth) PHED

inspected the Ajit Naiknaware (Jr. Ex)

(Name & Address of the school) on 8/5/2024 (date of inspection) and on the basis

of Water Test Report (Attached) bearing no 1242500001 Dated 8/5/2024

of (PHED Lab) certified that the Tilak

Maharashtra Vidyapeeth (Name of school) has safe drinking water

facilities for the students and members of staff of the institution. School is also maintains the

hygienic sanitation condition in the school building & the campus as per norms prescribed by

the Central/State/ U.T. Govt.

The certificate is valid till 7/5/2025

Signature with Seal: [Signature] 8/5/2024

Name: Ajit कनिष्ठ अभियंता Naiknaware.

Designation: स्वर्गट पाणीपुरवठा विभाग
जुम्हो महानगरपालिका

Name & Address of the Office / Department :

To
Tilak Maharashtra Vidyapeeth
Mukundnagar, Ghatge Road, Pune

(Name & Address of the Institution)

Executive Engr. No-01
Swargate water supply
Pune municipal corporation
Pune. 411005.

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies



PUNE MUNICIPAL CORPORATION

Date : 27/05/2024

Parvati Water Works Laboratory

Report ID : CH71

Report of Water Samples Collected as on 22/05/2024

Challan No : 12425000005 Challan Date : 22/05/2024 Amount (Rs.): 1620.0

पुणे महानगरपालिका
पर्वती जलकेंद्र पुणे ३०.
जावक क्र. - Lab no - CH-71
दिनांक - 27/05/2024

मालकाचे नाव : Tilak Maharashtra Vidyalyaya

1) Tilak Maharashtra Vidyalyaya, Tilak Maharashtra Vidyapeeth, Mukundnagar, Gultekdi, Pune -37 Drinking Water Sample

As per I.S Standard No. 10500:2012				
Parameter	Results	Desirable Limit	Permissible Limit	Unit
PH	7.56	Between 6.5 To 8.5	No Relaxation	-
Turbidity	0.9	Max 1	Max 5	N.T.U
Total Hardness (as CaCO ₃)	48.0	Max 200	Max 600	PPM
Chlorides (as Cl)	17.0	Max 250	Max 1000	PPM
Alkanity (as calcium carbonate)	95.0	Max 200	Max 600	PPM
Nitrate Nitrogen (as NO ₃)	0.4	Max 45	No relaxation	PPM
Nitrite Nitrogen (as NO ₂)	0.02	-	-	PPM
Coliform	0	0	0	100ml
E-Coli	0	0	0	100ml
Residual Chlorine Test	Nil	0.2	-	PPM

Remark : सदरचा नमुना / नमुने मालकांनी स्वतः आणून दिला. उपरोक्त नमुना / नमुने हा प्रातिनिधिक असल्याचे गृहीत धरले आहे. सदरचा अहवाल हा वैयक्तिक माहितीसाठी असून, याचा वापर कुठल्याही प्रकारचा परवान्यासाठी केल्याने उद्भवणाऱ्या कायदेशीर बाबींस हे कार्यालय जबाबदार असणार नाही. तसेच नमुनांच्या उद्दगमाविषयीचा पडताळा ह्या कार्यालयामार्फत केलेला नाही.

शेरा :

The Above Water Sample Is Potable as per IS:10500:2012

ASA 27/05/2024
केमिस्ट

पर्वती जलकेंद्र
पुणे महानगरपालिका